BID ADDENDUM

January 30, 2018

FAILURE TO RETURN THIS ENTIRE BID ADDENDUM IN ACCORDANCE WITH INSTRUCTIONS SHALL SUBJECT YOUR BID TO REJECTION ON THE AFFECTED ITEM(S):

 Contract ID:
 D6D3.POC.005
 WBS:
 6.102419.9

 TIP No.:
 County:
 Columbus

Federal Aid: State Funded Description: Pipe Removal & Replacement - SR 1740

Addendum No.: 1 Letting Date: February 7, 2018

Time: 2:00 PM

INSTRUCTIONS: A. Please make the following changes and adhere to the following

clarifications on the bid referenced above.

Proposed Amendments / Changes / Clarifications:

1. Page 27, Pipe Bedding Material, Measurement & Payment:

Charle ONLY and of the following extension and return and manually even the add and under

- a. Delete the following sentence "The stone will be measured by being weighed in trucks on certified platform scales or other certified weighing devices."
- b. Add the following sentence "The method of measurement will be by the truckload, as determined by the engineer, at 9 Tons per single axle truck, 15 Tons per tandem truck, 18 Tons per tri-axle truck and 20 per quad-axle truck."
- 2. Page 29, Aggregate Base Course, 4th paragraph:
 - a. Add the following sentence "The method of measurement will be by the truckload, as determined by the engineer, at 9 Tons per single axle truck, 15 Tons per tandem truck, 18 Tons per tri-axle truck and 20 per quad-axle truck."
- 3. Page 30, Patching, 5th paragraph:
 - a. Add the following sentences "A Paving Machine may be used, but is not required. Manual placement by hand, or other approved method, is acceptable."
- 4. A new Proposal has been created, titled "PROPOSAL REVISED 1/30/2018". Download and use this version for bidding. Discard any previous versions.

Addendum Execution:

(all pages) with the Bid Proposal, or have delivered prior to bid letting date & time.	
	Bid has already been mailed. Changes resulting from this addendum are as follows:
	Bid has already been mailed. NO CHANGES resulted from this addendum
	Bid has NOT been mailed and ANY CHANGES resulting from this addendum are included in our bid.
Changes (if any):	
<u>-</u>	
Contractor:	
Address:	
Authorized Agent:	Title:
Signature	Date:

Bidding by the submission of a Hard Copy:

Print Addendum, Fill out & Submit with Bid Package to:

R. Allen Waddell, PE - Division Proposals Engineer

NCDOT - Division 6

PO Box 1150 or 558 Gillespie Street Fayetteville, NC 28302 Fayetteville, NC 28301

or

Print Addendum, Fill out, Scan & Email, prior to Bid Opening Deadline, to:

R. Allen Waddell, PE - Division Proposals Engineer rawaddell@ncdot.gov

D6D3.POC.005 - Addendum 1.xlsx Page 1